



BIDS AND AWARDS COMMITTEE
Bid Bulletin No. 1 for 5th Public Bidding for CY2025

1. PROCUREMENT OF PROFESSIONAL SERVICES FOR THE STRUCTURAL INTEGRITY TEST OF THE DEPARTMENT OF ENERGY MAIN BUILDING FOR CY2025

Section VII. Technical Specifications

- Clarification for Scope of Works

2.7 Non-destructive test (NDT) of actual structural members shall be and but not limited to:

2.7.1 Testing of actual structural strength of column, beams, slab, footings.

2.7.2 Rebound hammer test shall be performed for every columns and main girders and cantilevers per floor.

2.7.3 Rebar scanning shall be performed on every column, beams, slab and footings.

All columns, shear walls, beams, girders, walls, and floor slabs of the building shall undergo Non-Destructive Testing (NDT) to ensure a comprehensive and accurate structural analysis, as well as the development of detailed engineering plans. This testing will help assess the integrity, strength, and durability of the structural components without causing any damage.

2.8 Destructive Testing (DT) Requires removing structural samples for laboratory analysis.

2.8.1 Core Sampling and Compression Testing

Additional evaluation through core sampling and compression test shall be done by SP. Three (3) samples for each area/ location shall be determined by the end-user based on the result of NDT. The SP shall be required to repair sample extraction points to restore the structural integrity of the affected elements.

2.9 The SP shall conduct geotechnical investigation of at least two (2) boreholes **per site** to determine the soil bearing capacity, liquefaction potential and settlement.

If any unfavorable test results arise, such as inadequate soil bearing capacity, high liquefaction potential, or excessive settlement, the SP shall be required to conduct additional boreholes as necessary to validate and confirm the findings. These additional investigations shall be carried out at no additional cost to the DOE to ensure accurate geotechnical assessments and proper foundation design recommendations.

2. PROCUREMENT OF SUPPLY AND DELIVERY OF EUMB's ICT EQUIPMENT UNDER NEECP AND AFTOP FOR CY2025

- None

3. PROCUREMENT OF SUPPLY AND DELIVERY OF ONE (1) LOT ICT EQUIPMENT UNDER ISSP FOR CY2025

Section VII. Technical Specifications

- Clarification for Technical Specifications

Item no.1 Clarification	Current Specification/ Provision	Revision
Audio and Mic	Audio by Poly Studio, dual stereo speakers with discrete amplifiers, integrated dual array microphones	Audio by Poly Studio , dual stereo speakers with discrete amplifiers, integrated dual array microphones
Accessories	Carry Bag	Backpack or Carry bag

This Bid Bulletin forms part of the Terms of Reference. All other terms and conditions in the Bid Documents and other Bid Bulletin issued by the DOE-BAC not inconsistent with this Supplemental/Bid Bulletin shall remain valid and effective.

Approved for Issuance:

(sgd)

GIOVANNI CARLO J. BACORDO
Undersecretary and Chairperson, BAC

DEBM/jjad/jcl